



Dy- UCC-4469
16/3/16

MAHARSHI DAYANAND UNIVERSITY, ROHTAK
(A State University established under Haryana Act. No.25/1975)
NAAC Accredited 'A' Grade

No. P&S/16/
Dt. 15/03/2016

Regd. / E-mail: Uniline@uniline.in

To

M/s Uniline Energy Systems (P) Ltd.,
Uniline House, 198/23,
Ramesh Market, East of Kailash,
New Delhi-110065.

Sub: AMC of On-Line UPS's.

Dear Sir,

Please refer to your letter no. UESPL-MDU-AMC-15-16/111 dated: 30 September 2015 on the subject cited above.

It is to inform you that the University authorities have approved/renewed the Maintenance Contract of Online UPS's 216+17=233 Nos. Various cap. installed in the various offices/departments of the University with your firm on the basis of terms & conditions of last contract w.e.f. 01/10/2015 to 31/03/2016 or till new arrangements. Your Resident engineer will paste sticker of your firm at on each UPS's which having detail i.e. Telephone No., Email for making complaint from time to time. The contract No. of your engineer may also be intimated for calling complaints from time to time. Your engineer will sit in the University Computer Centre and mark attendance every day under supervision of Director, University Computer Centre. A complaint register will also remain in the University Computer Centre.

As per your request your company will provide free of cost maintenance for the maintaining the 2 Static Swtich-15 KVA & 5 KVA.

You are, therefore, requested to get the contract papers prepared afresh on the applicable non-judicial stamp papers at the earliest having legal jurisdiction of Rohtak (in case of dispute, if any)

This may be treated as MOST URGENT.

Yours faithfully,

sd/
Officer on Special Duty (P&S)

Endst No. P&S/104/16/ 603 dated: 15/03/2016

A copy of the above is forwarded to the Director, Computer Centre, MDU, Rohtak for kind information and also requested to upload the same on the University Website (List appended)

Dee
Officer on Special Duty (P&S)

G. Samundha
15/3

CO


Temp page

PA 5-171
25/1/16


Paper in original may be
sent to incharge (PAS) for
necessary actions, for

Director, UCC


25/1/16


25/1/16

P/C (Res)
P-II


25/1/16

DETAILS FOR UNLITE UPS OF WAHARISHI DAYANAND UNIVERSITY, ROHTAK

Sr.NO.	Department	UPS CAPACITY	UPS SERIAL NO.	Battery Capacity	Nos. of Battery	UPS	Device position	Signature(Dept. Concerned)
1	GEOGRAPHY	5 KVA 192 V	ULK8058	12 AH/12V	6	UPS	Batteries	
2	GEOGRAPHY	2 KVA 192V	ULC10366	26 AH/12V	6	UPS	Batteries	
3	GEOGRAPHY	1 KVA 96 V	ULC10406	18 AH	6	UPS	Batteries	
4	GEOGRAPHY	1 KVA 96 V	ULC10389	18 AH	6	UPS	Batteries	
5	GEOGRAPHY	1 KVA 96 V	ULC10387	18 AH	6	UPS	Batteries	
6	GEOGRAPHY	1 KVA 96 V	ULC10386	18 AH	6	UPS	Batteries	
7	GEOGRAPHY	1 KVA 96 V	ULC10388	18 AH	6	UPS	Batteries	
8	MECHANICAL	5 KVA 192 V	ULC8382	42 AH	6	UPS	Batteries	
9	MECHANICAL	5 KVA 192 V	ULP9A428	42 AH	6	UPS	Batteries	
10	PHARMACEUTICAL	1 KVA 36 V	ULP9A464	11	6	UPS	Batteries	
11	PHARMACEUTICAL	1 KVA 36 V	ULP9A397	11	6	UPS	Batteries	
12	PHARMACEUTICAL	1 KVA 36 V	ULP9A421	11	6	UPS	Batteries	
13	PHARMACEUTICAL	1 KVA 36 V	ULP9A415	11	6	UPS	Batteries	
14	PHARMACEUTICAL	1 KVA 36 V	ULP9A413	11	6	UPS	Batteries	
15	PHARMACEUTICAL	1 KVA 36 V	ULP9A395	11	6	UPS	Batteries	
16	PHARMACEUTICAL	1 KVA 36 V	ULP9A481	11	6	UPS	Batteries	
17	PHARMACEUTICAL	1 KVA 36 V	ULP9A445	11	6	UPS	Batteries	
18	PHARMACEUTICAL	1 KVA 36 V	UL8A2105	11	6	UPS	Batteries	
19	PHARMACEUTICAL	1 KVA 36 V	UL8A2105	11	6	UPS	Batteries	
20	PHARMACEUTICAL	5 KVA 192 V	UL8A2105	42 AH	6	UPS	Batteries	
21	PHARMACEUTICAL	1 KVA 36 V	ULP9A432	42 AH	6	UPS	Batteries	
22	MAIN STORE (FINE ART HOD)	1 KVA 36 V	ULP9A450	42 AH	6	UPS	Batteries	
23	SOCIOLOGY	1 KVA 36 V	ULP9A417	42 AH	6	UPS	Batteries	
24	SOCIOLOGY	1 KVA 36 V	ULP9A453	42 AH	6	UPS	Batteries	
25	SOCIOLOGY	5 KVA 192 V	ULP9L181	42 AH	6	UPS	Batteries	
26	LAW	5 KVA 192 V	ULP9L183	42 AH	6	UPS	Batteries	
27	LAW	5 KVA 192 V	ULP9L182	42 AH	6	UPS	Batteries	
28	LAW	1 KVA 36 V	ULP9A	42 AH	6	UPS	Batteries	
29	LAW	1 KVA 36 V	ULP9A	42 AH	6	UPS	Batteries	
30	LAW	1 KVA 36 V	ULP9A	42 AH	6	UPS	Batteries	
31	LAW	1 KVA 36 V	ULP9A	42 AH	6	UPS	Batteries	
32	AMBEDKAR HALL	2 KVA 180 V	ULP9L375	18 AH	15	UPS	Batteries	
33	AMBEDKAR HALL	2 KVA 180 V	ULP9L375	18 AH	15	UPS	Batteries	
34	COMMERCE	1 KVA 36 V	ULP9A468	18 AH	6	UPS	Batteries	
35	COMMERCE	1 KVA 36 V	ULP9A448	18 AH	6	UPS	Batteries	
36	COMMERCE	5 KVA 192 V	UL9C6320	42 AH	6	UPS	Batteries	
37	COMMERCE	5 KVA 192 V	ULP9A458	42 AH	6	UPS	Batteries	
38	COMMERCE	1 KVA 36 V	ULP9A398	11	6	UPS	Batteries	
39	COMMERCE	1 KVA 36 V	ULP9A389	11	6	UPS	Batteries	
40	COMMERCE	1 KVA 36 V	ULP9A389	11	6	UPS	Batteries	
41	COMMERCE	1 KVA 36 V	ULP9A389	11	6	UPS	Batteries	
42	COMMERCE	1 KVA 36 V	ULP9A389	11	6	UPS	Batteries	
43	ECONOMICS	1 KVA 36 V	ULP9A454	11	6	UPS	Batteries	
44	ECONOMICS	1 KVA 36 V	ULP9A397	11	6	UPS	Batteries	
45	PHYSICS	1 KVA 36 V	ULP9A416	11	6	UPS	Batteries	
46	PHYSICS	1 KVA 36 V	ULP9A457	11	6	UPS	Batteries	

Sr. No.	Department	UPS CAPACITY	UPS SERIAL NO.	Battery Capacity	Nos. of Battery	Device position		Signature/Dept. Concern.
						UPS	Batteries	
47	PHYSICS	1 KVA 36 V	ULC10106	49 AH	6	OK	OK	
48	PHYSICS	1 KVA 36 V	ULC10109	11	6	OK	OK	
49	PHYSICS	1 KVA 36 V	ULC6324	11	6	OK	OK	
50	PHYSICS	1 KVA 36 V	ULC6323	11	6	OK	OK	
51	PHYSICS	1 KVA 36 V	ULC6322	49 AH	16	OK	OK	
52	PHYSICS	5 KVA 192 V	ULC6326	96 AH	16	OK	OK	
53	PHYSICS	2 KVA 120 V	UL9A404	49 AH	6	OK	OK	
54	GIRLS HOSTEL NO.1	1 KVA 36 V	ULP9A424	49 AH	6	OK	OK	
55	GIRLS HOSTEL NO.4	1 KVA 36 V	ULP9A425	49 AH	6	OK	OK	
56	DDE BUILDING	1 KVA 36 V	ULP9A409	11	6	OK	OK	
57	DDE BUILDING	1 KVA 36 V	ULP9A436	11	6	OK	OK	
58	DDE BUILDING	1 KVA 36 V	ULP9A447	11	6	OK	OK	
59	DDE BUILDING	1 KVA 36 V	ULP9A392	49 AH	6	OK	OK	
60	DDE BUILDING	1 KVA 36 V	ULL8178	49 AH	6	OK	OK	
61	DDE BUILDING	2 KVA 180 V		18 AH	6	OK	OK	
62	DDE BUILDING	5 KVA 192 V		49 AH	6	OK	OK	
63	DDE BUILDING	5 KVA 192 V		49 AH	6	OK	OK	
64	DDE BUILDING	2 KVA 96 V		100 AH	6	OK	OK	
65	DDE BUILDING	3 KVA 96 V		100 AH	6	OK	OK	
66	DDE BUILDING	2 KVA 180 V		18 AH	6	OK	OK	
67	IHTM	1 KVA 36 V	ULP9A94	49 AH	6	OK	OK	
68	IHTM	1 KVA 36 V	ULP9A430	49 AH	6	OK	OK	
69	IHTM	1 KVA 36 V	ULC10363	49 AH	6	OK	OK	
70	IHTM	1 KVA 36 V	ULC10408	49 AH	6	OK	OK	
71	IHTM	1 KVA 36 V	ULC10360	49 AH	6	OK	OK	
72	IHTM	1 KVA 36 V	ULP9A418	49 AH	6	OK	OK	
73	IHTM	1 KVA 36 V	ULC10400	49 AH	6	OK	OK	
74	IHTM	1 KVA 36 V	ULC10393	49 AH	6	OK	OK	
75	IHTM	2 KVA 192 V	ULC10369	49 AH	6	OK	OK	
76	IHTM	5 KVA 192 V	UL	49 AH	6	OK	OK	
77	IHTM	5 KVA 192 V	UL	49 AH	6	OK	OK	
78	IHTM	5 KVA 192 V	UL	49 AH	6	OK	OK	
79	IHTM	5 KVA 192 V	ULC10	49 AH	16	OK	OK	
80	IHTM	1 KVA 96 V	ULC10	18 AH	8	OK	OK	
81	IHTM	1 KVA 96 V	ULC10	18 AH	8	OK	OK	
82	IHTM	1 KVA 96 V	ULC10	18 AH	8	OK	OK	
83	IHTM	1 KVA 96 V	ULC10	18 AH	8	OK	OK	
84	IHTM	1 KVA 96 V	ULC10	18 AH	8	OK	OK	
85	EDUCATION	1 KVA 96 V	ULC10403	18 AH	8	OK	OK	
86	ENGLISH	2 KVA 192 V	ULC10367	96 AH	16	OK	OK	
87	ENGLISH	1 KVA 96 V	ULC10	49 AH	16	OK	OK	
88	COMPUTER LAB UIET	1 KVA 96 V	ULP9A443	49 AH	16	OK	OK	
89	COMPUTER LAB UIET	1 KVA 36 V	ULP9A443	49 AH	16	OK	OK	
90	COMPUTER LAB UIET	2 KVA 180 V	ULL8179	96 AH	16	OK	OK	
91	COMPUTER LAB UIET	2 KVA 180 V	ULL1180	96 AH	16	OK	OK	
92	COMPUTER LAB UIET	5 KVA 192 V	ULD748	49 AH	16	OK	OK	
93	COMPUTER LAB UIET	5 KVA 192 V	ULD747	49 AH	16	OK	OK	
94	COMPUTER LAB UIET	5 KVA 192 V	ULC6321	49 AH	16	OK	OK	

Signature/Dept. Concern.

Signature

Signature

Signature

Signature

Signature

Signature

Sr.NO.	Department	UPS CAPACITY	UPS SERIAL NO.	Battery Capacity	Nos. of Battery	UPS	Device position	Signature/(Dept. Concerned)
							Batteries	
95	COMPUTER LAB UIET	5 KVA 192V	ULF698		8	OK	Dead	
96	MCA COMPUTER LAB	3 KVA 96V	ULPC8154	120 AH	8	OK	Dead	
97	MCA COMPUTER LAB	5 KVA 180 V	ULPC8386	120 AH	15	OK	Dead	
98	MCA COMPUTER LAB	5 KVA 180 V	ULPC8382	120 AH	15	OK	Dead	
99	ACTION BRANCH	1 KVA 36 V	ULP9A408	40 AH	6	OK	Dead	
100	REGISTRAR RESIDENCE	1 KVA 36 V	ULP9A444	40 AH	6	OK	OK	
101	REGISTRAR RESIDENCE	1 KVA 36 V	ULP8A433	40 AH	6	OK	OK	
102	REGISTRAR RESIDENCE	1 KVA 36 V	UL		6	OK	OK	
103	REGISTRAR OFFICE	1 KVA 36 V	UL		6	OK	OK	
104	CVT	1 KVA 96V	ULC10100	18 AH	8	OK	Dead	
105	CVT	1 KVA 96V		11		OK	Dead	
106	CVT	1 KVA 96V		11		OK	Dead	
107	CVT	1 KVA 96V		11		OK	Dead	
108	CVT	1 KVA 96V		11		OK	Dead	
109	CVT	1 KVA 96V		11		OK	Dead	
110	CVT	2 KVA 192 V	ULC10361	18 AH	16	OK	Dead	
111	CVT	5 KVA 192 V	ULC110	40 AH	16	OK	Dead	
112	BIO SCIENCE	1 KVA 36 V	ULP9A174	40 AH	6	OK	Dead	
113	BIO SCIENCE	1 KVA 36V	ULP9A171	40 AH	6	OK	Dead	
114	BIO SCIENCE	1 KVA 36V	ULP9A171	40 AH	6	OK	Dead	
115	BIO SCIENCE	1 KVA 36 V	ULP9A181	40 AH	6	OK	Dead	
116	BIO SCIENCE	1 KVA 36 V	ULP9A173	40 AH	6	OK	Dead	
117	BIO SCIENCE	1 KVA 36 V	ULP9A179	40 AH	6	OK	Dead	
118	BIO TECHNOLOGY	1 KVA 96 V	ULC10384	18 AH	8	OK	Dead	
119	BIO TECHNOLOGY	1 KVA 96 V	ULC10391	11	8	OK	Dead	
120	BIO TECHNOLOGY	1 KVA 96 V	ULC10404	11	8	OK	Dead	
121	BIO TECHNOLOGY	1 KVA 96 V	ULC10115	11	8	OK	Dead	
122	BIO TECHNOLOGY	1 KVA 96 V	ULC10347	20 AH	11	OK	Dead	
123	BIO TECHNOLOGY	2 KVA 180 V	ULPF9054	90 AH	16	OK	Dead	
124	BIO TECHNOLOGY	5 KVA 192 V	ULC10385	90 AH	16	OK	Dead	
125	BIO TECHNOLOGY	2 KVA 192 V	ULC10362	90 AH	16	OK	Dead	
126	MICROBIO SCIENCE	1 KVA 96 V	ULC10116	18 AH	8	OK	Dead	
127	MICROBIO SCIENCE	1 KVA 96 V	ULC10386	18 AH	8	OK	Dead	
128	STATISTICS	1 KVA 96 V	ULC10110	18 AH	8	OK	Dead	
129	STATISTICS	2 KVA 192 V	ULC10318	90 AH	16	OK	Dead	
130	HOSTEL SATLUJ	1 KVA 36 V	ULP9A424	40 AH	6	OK	Dead	
131	GODAVARI HOSTEL	1 KVA 36 V	ULP9A446	11	6	OK	Dead	
132	SARASWATI HOSTEL	1 KVA 36 V	ULP9A422	11	6	OK	Dead	
133	SARASWATI HOSTEL	1 KVA 36 V	ULP9A412	11	6	OK	Dead	
134	HOSTEL NILGIRI	1 KVA 36 V	ULP9A459	40 AH	6	OK	Dead	
135	MATHMATICS	5 KVA 192 V	ULC8384	40 AH	16	OK	Dead	
136	MATHMATICS	5 KVA 192V	ULC8382	40 AH	16	OK	Dead	
137	MATHMATICS	1 KVA 36 V	ULP9A423	11	6	OK	Dead	
138	MATHMATICS	1 KVA 36 V	ULP9A440	11	6	OK	Dead	
139	MATHMATICS	1 KVA 96 V	ULC10112	10 AH	8	OK	Dead	
140	MATHMATICS	1 KVA 96 V	ULC10102	10 AH	8	OK	Dead	
141	MATHMATICS	5 KVA 192 V	ULC8383	40 AH	16	OK	Dead	
142	MATHMATICS	5 KVA 192 V	ULC8385	40 AH	16	OK	Dead	

Sr. NO.	Department	UPS CAPACITY	UPS SERIAL NO.	Battery Capacity	Nos. of Battery	Device position		Signature(Dept. Concerned)
						UPS	Batteries	
143	COMPUTER SCIENCE	2 KVA 120 V	ULD795					
144	COMPUTER SCIENCE	2 KVA 120 V	ULD796					
145	COMPUTER SCIENCE	5 KVA 180 V	ULX7297					
146	COMPUTER SCIENCE	2 KVA 96 V						
147	COMPUTER SCIENCE	2 KVA 96 V						
148	COMPUTER SCIENCE	2 KVA 96 V						
149	COMPUTER SCIENCE	2 KVA 96 V						
150	COMPUTER SCIENCE	2 KVA 96 V						
151	GIRLS HOSTEL SECURITY	1 KVA 96 V	ULC10103					
152	HEALTH CENTER	1 KVA 36 V	ULP9A442					
153	IMSAR	1 KVA 36 V	ULP9A460	42 AH	6	OK	OK	
154	IMSAR	1 KVA 36 V	ULP9A431	42 AH	6	OK	OK	
155	IMSAR	1 KVA 36 V	ULP9A405	42 AH	6	OK	OK	
156	IMSAR	1 KVA 36 V	ULP9L124	42 AH	6	OK	OK	
157	IMSAR	3 KVA 96 V	ULP8L175	120 AH	8	OK	OK	
158	IMSAR	5 KVA 180 V	ULC6318	42 AH	16	OK	OK	
159	IMSAR	5 KVA 180 V	ULC6325	42 AH	16	OK	OK	
160	PRESS	1 KVA 36 V	ULP9A401	42 AH	16	OK	OK	
161	ECONOMICS	1 KVA 36 V	ULP9A397					
162	ACCOUNT	3 KVA 96 V	UL9A13					
163	GIRLS HOSTEL WARDEN	1 KVA 96 V	ULC10392					
164	CENTRAL LIBRARY	5 KVA 192 V	ULC8402	42 AH		OK	OK	
165	CENTRAL LIBRARY	5 KVA 192 V	ULC6319	42 AH		OK	OK	
166	CENTRAL LIBRARY	5 KVA 192 V	ULK7065	42 AH		OK	OK	
167	CENTRAL LIBRARY	5 KVA 192 V	ULC10355	42 AH		OK	OK	
168	CENTRAL LIBRARY	5 KVA 192 V	UL	42 AH		OK	OK	
169	CENTRAL LIBRARY	15 KVA 360 V	ULC8184	42 AH	128	OK	OK	
170	CENTRAL LIBRARY	15 KVA 360 V	ULC8186	42 AH	128	OK	OK	
171	CENTRAL LIBRARY	STRATIC	ULC8185	42 AH		OK	OK	
172	CENTRAL LIBRARY	1 KVA 36 V	ULP9A407	42 AH		OK	OK	
173	CENTRAL LIBRARY	1 KVA 36 V	ULP9A411	42 AH		OK	OK	
174	CENTRAL LIBRARY	1 KVA 36 V	ULP9A394	42 AH		OK	OK	
175	CENTRAL LIBRARY	1 KVA 96 V	ULPC1038	42 AH		OK	OK	
176	CENTRAL LIBRARY	1 KVA 36 V	ULP9A407	42 AH		OK	OK	
177	CENTRAL LIBRARY	1 KVA 36 V	ULP9A396	42 AH		OK	OK	
178	CENTRAL LIBRARY	1 KVA 36 V	ULP9A438	42 AH		OK	OK	
179	CENTRAL LIBRARY	1 KVA 96 V	ULPC10399	120 AH		OK	OK	
180	CENTRAL LIBRARY	1 KVA 96 V		120 AH		OK	OK	
181	CENTRAL LIBRARY	1 KVA 96 V	ULPC10	120 AH		OK	OK	
182	CENTRAL LIBRARY	3 KVA 96 V	ULP8E176	120 AH		OK	OK	
183	LAW LIBRARY	1 KVA 96 V	ULP9A			OK	OK	
184	LAW LIBRARY	1 KVA 96 V	ULP9A			OK	OK	
185	LAW LIBRARY	1 KVA 96 V	ULP9A			OK	OK	
186	FACULTY HOUSE	1 KVA 36 V	ULP9A			OK	OK	
187	FACULTY HOUSE	1 KVA 36 V	ULP9A			OK	OK	
188	FACULTY HOUSE	1 KVA 36 V	ULP9A			OK	OK	
189	PSYCHOLOGY	1 KVA 36 V	ULP9A453					
190	PSYCHOLOGY	1 KVA 36 V	ULP9A417					

Signature
11/10/15

Signature
11/10/15

Sr. NO.	Department	UPS CAPACITY	UPS SERIAL NO.	Battery Capacity	Nos. of Battery	Device position		Signature (Dept. Concerned)
						UPS	Batteries	
191	GIRLS HOSTEL GANGA	1 KVA 36 V	ULP9A404	11	6	OK	OK	
192	UIT NEW BUILDING	1 KVA 36 V	ULP9A	11	6	OK	OK	
193	UIT NEW BUILDING	1 KVA 36 V	ULP9A	11	6	OK	OK	
194	UIT NEW BUILDING	1 KVA 36 V	ULP9A	11	6	OK	OK	
195	UIT NEW BUILDING	1 KVA 36 V	ULP9A	11	6	OK	OK	
196	UIT NEW BUILDING	1 KVA 36 V	ULC10	11	6	OK	OK	
197	UIT NEW BUILDING	1 KVA 96 V	ULC10	11	6	OK	OK	
198	UIT NEW BUILDING	1 KVA 96 V	ULC10	11	6	OK	OK	
199	UIT NEW BUILDING	1 KVA 96 V	ULP9A	11	6	OK	OK	
200	STADIUM	1 KVA 36 V	ULP9A	11	6	OK	OK	
201	STADIUM	1 KVA 36 V	ULP9A	11	6	OK	OK	
202	V.C. RESIDENCE	1 KVA 36 V	ULP9A	11	6	OK	OK	
203	ELECTRICAL	1 KVA 36 V	ULP9A	11	6	OK	OK	
204	ELECTRICAL	1 KVA 36 V	ULP9A	11	6	OK	OK	
205	BIOTECHNOLOGY	1 KVA 96 V	ULC10384	11	6	OK	OK	
206	BIOTECHNOLOGY	1 KVA 96 V	ULC10391	11	6	OK	OK	
207	BIOTECHNOLOGY	1 KVA 96 V	ULC10404	11	6	OK	OK	
208	BIOTECHNOLOGY	1 KVA 96 V	ULC10115	11	6	OK	OK	
209	BIOTECHNOLOGY	1 KVA 96 V	ULC10347	11	6	OK	OK	
210	BIOTECHNOLOGY	1 KVA 96 V	ULC10110	11	6	OK	OK	
211	LAW LIBRARY	1 KVA 36 V	ULP9A	11	6	OK	OK	
212	LAW LIBRARY	1 KVA 96 V	ULC10	11	6	OK	OK	
213	LAW LIBRARY	1 KVA 96 V	ULC10	11	6	OK	OK	
214	NASA DEPARTEMENT	1 KVA 96 V	ULC10	11	6	OK	OK	
215	NASA DEPARTEMENT	1 KVA 96 V	ULC10	11	6	OK	OK	
216	COMPUTER CENTER	1 KVA 96 V	ULC10	11	6	OK	OK	
217	COMPUTER CENTER	2 KVA 120 V		11	6	OK	OK	
218	COMPUTER CENTER	2 KVA 120 V		11	6	OK	OK	
219	COMPUTER CENTER	5 KVA 192 V	ULP9L396	11	6	OK	OK	
220	BIO-CHEMISTRY	1 KVA 36 V	ULP9L441	11	6	OK	OK	
221	BIO-CHEMISTRY	1 KVA 36 V	2K10D001	11	6	OK	OK	
222	MCA COMPUTER LAB	3KVA 96V	2K10D002	11	6	OK	OK	
223	MCA COMPUTER LAB	3KVA 96V	2K10D003	11	6	OK	OK	
224	MCA COMPUTER LAB	3KVA 96V	ULP13L006	11	6	OK	OK	
225	LIBRARY & INFORMATION SC.	5KVA 180V	ULP13L001	11	6	OK	OK	
226	GENETICS DEPT.	5KVA 180V	ULP13L002	11	6	OK	OK	
227	GENETICS DEPT.	5KVA 180V	ULP13L003	11	6	OK	OK	
228	GENETICS DEPT.	5KVA 180V	ULP13L004	11	6	OK	OK	
229	GENETICS DEPT.	5KVA 180V	ULP13L005	11	6	OK	OK	
230	GENETICS DEPT.	5KVA 180V	2K13 I 3623	11	6	OK	OK	
231	GENETICS DEPT.	3KVA 96V	2K14A 436	11	6	OK	OK	
232	GENETICS DEPT.	1KVA 36 V	ULP9A455	11	6	OK	OK	
233	DDE BUILDING (ROOM NO.129	1KVA 36 V		11	6	OK	OK	

Signature
1/10/11

Signature
1/10/11

Signature
1/10/11

Signature
1/10/11

Signature
1/10/11

Signature
1/10/11